

School:	General Louis Wagner Middle School		
Vendor:	EMCORE Fluidics		
Please visit https://bit.ly/3mA7rMY for more information on how to read this report.			
Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)
101A	classroom	312.0	20
101B	classroom	376.0	25
102	classroom	644.0	42
103A	classroom	1,312.0	87
103B	classroom	579.0	38
MEDIA LAB A	classroom	304.0	20
MEDIA LAB B	classroom	564.0	37
111	classroom	536.0	35
112	classroom	585.0	39
201	classroom	973.0	64
202	classroom	907.0	60
203	classroom	306.0	20
204	classroom	600.0	40
205A	Counselor Office	597.0	39
205B	Counselor Office	690.0	46
Cafeteria	Cafeteria	498.0	33
Main Office	Main Office	632.0	42
Conf. Room	Conf. Room	884.0	58
219	classroom	1,463.0	97
220	classroom	731.0	48
221	classroom	1,653.0	110
222	classroom	667.0	44
225	Dean	272.0	18
226	classroom	671.0	44
Boy's Gym	Boy's Gym	5,914.0	394
Boy's Gym	Boy's Gym	2,575.0	171
Boy's Gym	Boy's Gym	3,011.0	200
Boy's Gym	Boy's Gym	3,124.0	208
301	classroom	620.0	41
302	classroom	1,076.0	71
303	classroom	1,417.0	94
304A	classroom	646.0	43
304B	classroom	1,021.0	68
305	classroom	1,926.0	128
306	classroom	1,674.0	111
307	classroom	482.0	32
319	classroom	1,541.0	102
320	classroom	2,179.0	145

School:	General Louis Wagner Middle School		
Vendor:	EMCORE Fluidics		
Please visit https://bit.ly/3mA7rMY for more information on how to read this report.			
Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)
321	classroom	1,712.0	114
322	classroom	40.0	2
325	classroom	494.0	32
326	classroom	481.0	32
105	classroom	527.0	35
106	classroom	713.0	47
107	classroom	635.0	42
108	classroom	586.0	39
Weight Room A	classroom	1,230.0	82
Weight Room B	classroom	1,164.0	77
112 Girl's Gym	classroom	2,194.0	146
112 Girl's Gym	classroom	2,052.0	136
112 Girl's Gym	classroom	784.0	52
112 Girl's Gym	classroom	3,597.0	239
Lunch Room	classroom	175.0	11
209A	classroom	496.0	33
VP Office	classroom	1,325.0	88
212	classroom	1,030.0	68
213	classroom	870.0	58
214	classroom	446.0	29
215	classroom	240.0	16
216	classroom	2,170.0	144
217	classroom	1,626.0	108
218	classroom	197.0	13
Computer Lab	classroom	446.0	29
Staff Lounge	?	421.0	28
301	classroom	662.0	44
302	classroom	1,148.0	76
303	classroom	1,512.0	100
304A	classroom	689.0	45
305	classroom	2,055.0	137
306	classroom	1,787.0	119
307	classroom	514.0	34
308	classroom	1,202.0	80
309	classroom	2,171.0	144
310	classroom	2,047.0	136
311A	classroom	990.0	66
312	classroom	211.0	14

School:	General Louis Wagner Middle School		
Vendor:	EMCORE Fluidics		
Please visit https://bit.ly/3mA7rMY for more information on how to read this report.			
Classroom ID / Area ID Number	Classroom / Area Type supplied	Actual Outside Air CFM (OA)	Occupancy (OA CFM / 15)
313	classroom	868.0	57
314	classroom	350.0	23
315	classroom	83.0	5
316	classroom	1,078.0	71
317	classroom	1,382.0	92
318	classroom	1,811.0	120
319	classroom	1,644.0	109
320	classroom	2,325.0	155
321	classroom	1,826.0	121
322	classroom	42.0	2
323	classroom	1,074.0	71
324	classroom	909.0	60
325	classroom	527.0	35
326	Counselor Office	513.0	34
N/A	Auditorium	0.0	0
Kitchen	Kitchen	0.0	0
Kitchen	Freezer/Cooler Condenser Fan	0.0	0
Kitchen	MUA for Kitchen	5,749.0	383
209B	classroom	763.0	50
209C	classroom	995.0	66
304B	classroom	1,089.0	72
311B	classroom	782.0	52